

Construction Inspection Sign-off Card

NOTE: THIS PERMIT CARD AND ALL APPROVED/UCDFD STAMPED PLANS SHALL BE KEPT ON JOB SITE IN INSPECTOR'S OFFICE AT ALL TIMES. INSPECTIONS SHALL BE SCHEDULED BY PROJECT MANAGER OR PROJECT INSPECTOR.

PROJECT NAME:	PLAN REVIEWER/INSPECTOR:
PROJECT NUMBER:	DATE:
	PROJECT MANAGER:

REQUIREMENT	FAIL	PASS	UCFD INIT.	Date	REQUIREMENT	FAIL	PASS	UCFD INIT.	Date
APPROVED PLANS ON SITE					RATED CONSTRUCTION: [FINAL]				
SITE DETAILS: [FINAL]					SCREWS				
FIRE LANES/ACCESS					LAYERS				
*HYDRANTS: LOCATION, FLUSH, FLOWED, PAINTED, NUMBERED, STREET VALVES OPENED					HEAD OF WALL				
FIRE SPRINK. UNDERGROUND: [FINAL]					PENETRATIONS: SLEEVES, MATERIALS				
PIPING; INDICATING VALVES					DAMPERS				
THRUST BLOCKS; 200# HYDRO and FLUSH					EXITING: [FINAL]				
FDC: LOCATION, FLUSH, PAINTED, I.D.					CORRIDOR CLEARANCE				
*NFPA 24 CERTIFICATION RECEIVED					RECYCLE CONTAINERS				
OV/HD FIRE SPRINK. SYS: [FINAL]					RATED DOORS, FRAMES				
RISER					HARDWARE, CLOSERS, CARD KEY				
PIPING & HANGERS VISUAL					EXIT SIGNAGE/TACTILE SIGNAGE				
E.Q. BRACING					EMERGENCY ILLUMINATION				
200# HYDRO					OCCUPANT LOAD SIGNAGE				
PARTIAL SYS. 150# HYDRO					EVACUATION SIGNAGE				
FINISHED CEILING VISUAL					STAIR VISUAL IDENTIFICATION				
AT FINAL: CALC PLATE, VALVE SIGNS,					HANDRAILS, GUARDRAILS				
HEAD BOX, NFPA 13 TEST CERT. FORM					H OCCUPANCY REQUIREMENTS MET:				
					SPRAY BOOTHS				
STANDPIPE: LOCATION & ROOF CONN.					LABS				
FIRE PUMP TEST					HAZARDOUS MATERIALS STORAGE				
HOOD SYSTEMS: [FINAL]					STORAGE				
MANUAL PULL and LINK					SIGNAGE				
GAS OR ELECTRICAL SHUT OFF					USE				
PIPING					MEDICAL GAS SYSTEMS: [FINAL]				
CONNECTION TO ALARM SYSTEM					PIPING VISUAL				
CLASS K/40BC EXTINGUISHER INSTALLED					PIPING PRESSURE TEST				
FIRE ALARM SYSTEM: [FINAL]					VALVES				
ELECTRICAL INSPECTOR FINAL ACCEPTANCE					ALARMS				
NFPA 72 PRE-TEST COMPLETED									
SMOKE and/or HEAT DETECTORS					FIRE EXTINGUISHERS				
PULL STATIONS					FIRE DOOR/WINDOW/CURTAIN				
REMOTE ANNUNCIATOR					SMOKE DETECTORS OR LINKS				
AUDIBLES/VISUALS					STAGES				
DUCT DET. /DAMPERS /RESET SWITCHES					FABRIC FLAMMABILITY (TB117/TB133)				
ELEVATOR RECALL					FURNISHINGS (TITLE 19 REQ.)				
DOOR RELEASE					EMERGENCY GENERATOR TEST				
EXTERIOR BELL					KNOX BOX FINALED				
WATERFLOW ALARM					ADDRESS POSTED PER SPECS				
BATTERY TEST					LEASED SPACE APPROVED				
NFPA 72 COMPLETION FORMS									
LABELING OF DEVICES									

NOTE: OCCUPANCY SHALL NOT BE GRANTED WITHOUT A UCDFD FIRE CLEARANCE

PROJECT INSP. OR or MGR. SIGN OFF:	DATE:	UCDFD FIRE CLEARANCE GRANTED BY:	DATE:
------------------------------------	-------	----------------------------------	-------