



FIRENET

UCDAVIS



FIRE DEPARTMENT

GUIDELINES FOR MATERIALS AND OBJECTS PERMITTED IN CORRIDORS

Type of Material or Object:	Type of Corridor		
	Exit Enclosure	Rated Corridor	Unrated Corridor
Vending Machines	Not permitted	Not permitted	Permitted*
Furniture, fixed, non-combustible	Not permitted	Permitted*	Permitted*
Furniture, fixed, combustible	Not permitted	Not permitted	Permitted*
Furniture, non-fixed, non-combustible	Not permitted	Not permitted	Permitted*
Furniture, non-fixed, combustible	Not permitted	Not permitted	Permitted*
Recycling containers, fixed, non-combustible, with self-closing lid	Not permitted	Permitted*	Permitted*
If fixed and non-combustible: structural members, exhibits, display objects, artwork	Permitted*	Permitted*	Permitted*
If fixed and non-combustible: eyewashes, emergency showers, water fountains, metal lockers for personal use	Not permitted	Permitted*	Permitted*
Display cases containing non-combustible or limited combustible materials behind glass doors	Not permitted	Permitted without limitation on area*	Permitted without limitation on area*
Bulletin or tack boards with combustible display materials	Not permitted	Permitted up to 10% of the wall area	Permitted without limitation on area*
Equipment, freezers, refrigerators, storage units or any other object or material not specifically listed above	Not permitted	Not permitted	Permitted*

*Shall not encroach into minimum required exit width AND shall not create an obstruction AND shall not intrude into the total corridor width by more than 3”.